

## Sec. 3.36. Water Meters

### A. Application

**A.1.** - This code applies to devices used for the measurement of water; generally applicable to, but not limited to, utilities type meters installed in homes or business establishments and meters installed in batching systems.

**A.2.** - This code does not apply to:

- (a) water meters mounted on vehicle tanks (for which see Sec. 3.31; Code for Vehicle-Tank Meters).
- (b) mass flow meters (see Sec. 3.37. Code for Mass Flow Meters)  
(Added 1994)

**A.3.** - See also Sec. 1.10; General Code requirements.

### S. Specifications

#### S.1. Design of Indicating and Recording Elements and of Recorded Representations.

##### S.1.1. Primary Elements.

**S.1.1.1. General.** - A water meter shall be equipped with a primary indicating element and may also be equipped with a primary recording element.

**S.1.1.2. Units.** - A water meter shall indicate and record, if the device is equipped to record, its deliveries in terms of liters, gallons or cubic feet or binary or decimal subdivisions thereof except batch plant meters, which shall indicate deliveries in terms of liters, gallons or decimal subdivisions of the liter or gallon only.

**S.1.1.3. Value of Smallest Unit.** - The value of the smallest unit of indicated delivery and recorded delivery, if the device is equipped to record, shall not exceed the equivalent of:

- (a) 50 L (10 gal) on utility type meters,
- (b) 0.2 L (1/10 gal) on batching meters delivering less than 375 L/min (100 gal/min), or

- (c) 5 L (1 gal) on batching meters delivering 375 L/min (100 gal/min) or more.

**S.1.1.4. Advancement of Indicating and Recording Elements.** - Primary indicating and recording elements shall be susceptible to advancement only by the mechanical operation of the device.

**S.1.1.5. Return to Zero.** - If the meter is so designed that the primary indicating elements are readily returnable to a definite zero indication, means shall be provided to prevent the return of these elements beyond their correct zero position.

##### S.1.2. Graduations.

**S.1.2.1. Length.** - Graduations shall be so varied in length that they may be conveniently read.

**S.1.2.2. Width.** - In any series of graduations, the width of a graduation shall in no case be greater than the width of the minimum clear interval between graduations, and the width of main graduations shall be not more than 50 percent greater than the width of subordinate graduations. Graduations shall in no case be less than 0.2 mm (0.008 in) in width.

**S.1.2.3. Clear Interval Between Graduations.** - The clear interval shall not be less than 1.0 mm (0.04 in). If the graduations are not parallel, the measurement shall be made:

- (a) along the line of relative movement between the graduations at the end of the indicator, or
- (b) if the indicator is continuous, at the point of widest separation of the graduations.

##### S.1.3. Indicators.

**S.1.3.1. Symmetry.** - The index of an indicator shall be symmetrical with respect to the graduations, at least throughout that portion of its length associated with the graduations.

**S.1.3.2. Length.** - The index of an indicator shall reach to the finest graduations with which it is used,

the width of the minimum clear interval between graduations, and the width of main graduations shall be not more than 50 percent greater than the width of subordinate graduations. Graduations shall in no case be less than 0.2 mm (0.008 in) in width.

**S.1.2.3. Clear Interval Between Graduations.** - The clear interval shall not be less than 1.0 mm (0.04 in). If the graduations are not parallel, the measurement shall be made:

- (a) along the line of relative movement between the graduations at the end of the indicator, or
- (b) if the indicator is continuous, at the point of widest separation of the graduations.

### **S.1.3. Indicators.**

**S.1.3.1. Symmetry.** - The index of an indicator shall be symmetrical with respect to the graduations, at least throughout that portion of its length associated with the graduations.

**S.1.3.2. Length.** - The index of an indicator shall reach to the finest graduations with which it is used, unless the indicator and the graduations are in the same plane, in which case the distance between the end of the indicator and the ends of the graduations, measured along the line of the graduations, shall be not more than 1.0 mm (0.04 in).

**S.1.3.3. Width.** - The width of the index of an indicator in relation to the series of graduations with which it is used shall not be greater than:

- (a) the width of the widest graduation, and
- (b) the width of the minimum clear interval between graduations.

When the index of an indicator extends along the entire length of a graduation, that portion of the index of the indicator that may be brought into coincidence with the graduation shall be of the same width throughout the length of the index that coincides with the graduation.

**S.1.3.4. Clearance.** - The clearance between the index of an indicator and the graduations shall in no case be more than 1.5 mm (0.06 in).

**S.1.3.5. Parallax.** - Parallax effects shall be reduced to the practicable minimum.

## **S.2. Design of Measuring Elements.**

**S.2.1. Provision for Sealing.** - Adequate provision shall be made for applying security seals in such a manner that no adjustment may be made of:

- (a) any measurement elements, and
- (b) any adjustable element for controlling delivery rate when such rate tends to affect the accuracy of deliveries.

The adjusting mechanism shall be readily accessible for purposes of affixing a security seal.

### **S.2.2. Batching Meters Only.**

**S.2.2.1. Air Elimination.** - Batching meters shall be equipped with an effective air eliminator.

**S.2.2.2. Directional Flow Valves.** - Valves intended to prevent reversal of flow shall be automatic in operation.

## **N. Notes**

**N.1. Test Liquid.** - A meter shall be tested with water.

**N.2. Evaporation and Volume Change.** - Care shall be exercised to reduce to a minimum, evaporation losses and volume changes resulting from changes to temperature of the test liquid.

**N.3. Test Drafts.** - Test drafts should be equal to at least the amount delivered by the device in 2 minutes and in no case less than the amount delivered by the device in 1 minute at the actual maximum flow rate developed by the installation. The test drafts shown in Table 1, next page, shall be followed as closely as possible.

### **N.4. Testing Procedures.**

**N.4.1. Normal Tests.** The normal test of a meter shall be made at the maximum discharge rate developed by the installation. Meters with maximum gallon per minute ratings higher than Table 1 values may be tested up to the meter rating.  
(Amended 1990)

**N.4.2. Special Tests.** - Special tests to develop the operating characteristics of meters may be made according to the rates and quantities shown in Table 2.

**N.4.3. Batching Meter Tests.** - Tests on batching meters should be conducted at the maximum and intermediate rates only.

### T. Tolerances

**T.1. Tolerance Values.** - Maintenance and acceptance tolerances shall be as shown in Table 1 and Table 2.

### UR. User Requirements

#### UR.1. Batching Meters Only.

**UR.1.1. Strainer.** - A filter or strainer shall be provided if it is determined that the water contains excessive amounts of foreign material.

**UR.1.2. Siphon Breaker.** - An automatic siphon breaker or other effective means shall be installed in the discharge piping at the highest point of outlet, in no case below the top of the meter, to prevent siphoning of the meter and permit rapid drainage of the pipe or hose.

**UR.1.3. Provision for Testing.** - Acceptable provisions for testing shall be incorporated into all meter systems. Such provisions shall include a two-way valve, or manifold valving, and a pipe or hose installed in the discharge line accessible to the proper positioning of the test measure.

Table 1. Tolerances for Water Meters				
Normal Tests				
Meter size (inches)	Rate of flow (gal/min)	Maximum Rate		
		Meter indication		Tolerance on over- and under- registration
		gal	ft <sup>3</sup>	
5/8	15	50	5	1.5%
3/4	25	50	5	
1	40	100	10	
1 1/2	80	300	40	
2	120	500	40	
3	250	500	50	
4	350	1 000	100	
6	700	1 000	100	

## 3.36. Water Meters

Table 2. Tolerances for Water Meters Special Tests									
Meter size (inches)	Intermediate Rate				Minimum Rate				
	Rate of flow (gal/ min)	Meter indication		Tolerance on over- and un- derregis- tration	Rate of flow (gal/ min)	Meter indication		Tolerance	
		gal	ft <sup>3</sup>			gal	ft <sup>3</sup>	Under- registra- tion	Over- regis- tration
5/8	2	10	1	1.5%	1/4	5	1	5.0%	1.5%
3/4	3	10	1		1/2	5	1		
1	4	10	1		3/4	5	1		
1 1/2	8	50	5		1 1/2	10	1		
2	15	50	5		2	10	1		
3	20	50	5		4	10	1		
4	40	100	10		7	50	5		
6	60	100	10		12	50	5		